

Telephone: 0471-2473844

Fax : 0471-2473844

Email: kspcbdotvm@yahoo.co.in

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

ജില്ലാ ഓഫീസ്, തിരുവനന്തപുരം

KERALA STATE POLLUTION CONTROL BOARD

DISTRICT OFFICE, THIRUVANANTHAPURAM

T C.30/881, (NEAR KARTHIKA THEATRE), PETTAH P.O, THIRUVANANTHAPURAM - 695 024

PCB/TVM/DO/L/T&S/07


05/02/2008

ANALYSIS REPORT

SAMPLES RECEIVED FROM KSUDP ON 31/01/2008.

Ref:- Your letter No. 2007043/1436 dated 04/01/2008

Sl.No.	Determinant	Unit	Sewage coming into the farm[Inlet]	Sewage coming out the farm[Outlet]
1	BOD,[3 day at 27°C]	Mg/l	182	154
2	COD	Mg/l	400	464
3	pH		6.03	6.2
4	Temperature	°C	30	30
5	Suspended Solids	Mg/l	270	318
6	Volatile Solids	Mg/l	61	48
7	Nitrates	Mg/l	BDL	BDL
8	Phosphates as P	Mg/l	1.56	1.72


R.JAYAKUMAR
ASST.ENVIRONMENTAL SCIENTIST